

# Test Verification of Conformity

Verification Number: 210403960SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Afore New Energy Technology (Shanghai)Co., Ltd. Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China 201112
Product Description:	Grid-connected PV inverter
Ratings & Principle Characteristics:	See Appendix(Specifications table)
Models/Type References:	See Appendix(Specifications table)
Brand Name:	Afore
Relevant Standards:	VDE-AR-N 4105:2018 conjunction with DIN VDE V 0124-100 :2020
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2021-04-29 to 2021-05-21
Test Report Number(s):	210403960SHA-001
Additional information in Appendix.	

## Signature



**Name: Jonny Jing**  
**Position: Manager**  
**Date: 2021-05-21**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 210403960SHA-V1

Manufacturer: Same as applicant

Specifications table			
Model	HNS1000TL-1	HNS1500TL-1	HNS2000TL-1
<b>Input:</b>			
Vmax PV (Vdc)	500	500	500
Isc PV (absolute Max.) (A)	18	18	18
Number MPP trackers	1	1	1
Number input strings	1	1	1
Max. PV input current(A)	14	14	14
MPPT voltage range (Vdc)	50-500	50-500	50-500
Vdc range @ full power (Vdc)	70-500	110-500	145-500
<b>Output</b>			
Normal Voltage(V)	L/N/PE, 220Vac, 230Vac, 240Vac		
Frequency (Hz)	50 / 60		
Current (normal) (A)	4.4	6.6	8.7
Current (Max. continuous) (A)	6	9	12
Power rating (W)	1000	1500	2000
Power Rating (VA)	1000	1500	2000
Power factor /rated	1 (-0,8~+0,8 adjustable)	1 (-0,8~+0,8 adjustable)	1 (-0,8~+0,8 adjustable)
<b>others</b>			
Protective class	Class I		
Ingress protection (IP)	IP 65		
Temperature (°C)	-25°C to +60°C (up 45°C derating)		
Inverter Isolation	Non-isolated		
Overvoltage category	OVC III (AC Main), OVC II (PV)		
Weight (kg)	6		
Dimensions (WxHxD) (mm)	260 x 280 x 116		

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Specifications table			
Model	HNS2500TL-1	HNS3000TL-1	
<b>Input:</b>			
Vmax PV (Vdc)	500	500	
Isc PV (absolute Max.) (A)	18	18	
Number MPP trackers	1	1	
Number input strings	1	1	
Max. PV input current(A)	14	14	
MPPT voltage range (Vdc)	50-500	50-500	
Vdc range @ full power (Vdc)	180-500	220-500	
<b>Output</b>			
Normal Voltage(V)	L/N/PE, 220Vac, 230Vac, 240Vac		
Frequency (Hz)	50 / 60		
Current (normal) (A)	10.9	13.1	
Current (Max. continuous) (A)	13	15	
Power rating (W)	2500	3000	
Power Rating (VA)	2500	3000	
Power factor /rated	1(-0,8~0,8 adjustable)	1(-0,8~0,8 adjustable)	
<b>others</b>			
Protective class	Class I		
Ingress protection (IP)	IP 65		
Temperature (°C)	-25°C to +60°C (up 45°C derating)		
Inverter Isolation	Non-isolated		
Overvoltage category	OVC III (AC Main), OVC II (PV)		
Weight (kg)	6		
Dimensions (WxHxD) (mm)	260 x 280 x 116		

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

#### Annex E4: Verification of Conformity for power generation units

<b>Verification of Conformity for power generation units</b>	No: 210403960SHA-V1		
<b>Manufacturer</b>	Afore New Energy Technology (Shanghai)Co., Ltd. Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China 201112		
<b>Type power generation unit</b>	Grid-connected PV inverter		
<b>Model</b>	HNS1000TL-1, HNS1500TL-1, HNS2000TL-1, HNS2500TL-1, HNS3000TL-1		
<b>Assessment values</b>	Max. active power P <sub>E</sub> max (W)	1040	HNS1000TL-1
		3037	HNS3000TL-1
	Max. apparent power S <sub>E</sub> max (VA)	1056	HNS1000TL-1
		3052	HNS3000TL-1
	Rated voltage	1/N/PE~ 230Vac	
<b>Network connection rules</b>	<b>VDE-AR-N 4105 "Power generation systems connected to the low-voltage network"</b> Technical minimum requirements for connection and parallel operation of power generation systems connected to the low voltage network		
<b>Firmware version</b>	V06		
The above mentioned power generation unit meets the requirements of VDE-AR-N 4105.			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

### Annex E.5 Test report “Network interactions” for power generation units

Model: HNS3000TL-1

Extract from the test report on the certificate of units		210403960SHA-001											
Type of installation:	Grid-connected PV inverter	Manufacturer 's data											
Installation manufacturer:	Afore New Energy Technology(Shanghai) Co., Ltd.	Type of installation: Grid-connected PV inverter											
		Power of normal output in nominal conditions):3000 W											
		Rating voltage: 230 V											
Period of measurement:	From 2021-04-29 to 2021-05-21												
		Maximum active Power $P_{E_{max}}$ 3037 W	Maximum reactive Power $S_{E_{max}}$ 3052 VA										
		Switching actions	<table border="1"> <tr> <td><math>k_f</math></td> <td>0.15</td> </tr> <tr> <td><math>k_f</math></td> <td>0.15</td> </tr> <tr> <td><math>k_f</math></td> <td>0.14</td> </tr> <tr> <td><math>k_f</math></td> <td>0.31</td> </tr> <tr> <td><math>k_{fmax}</math></td> <td>0.31</td> </tr> </table> <p>The limit of <math>k_{fmax}</math> is 1.0</p>	$k_f$	0.15	$k_f$	0.15	$k_f$	0.14	$k_f$	0.31	$k_{fmax}$	0.31
$k_f$	0.15												
$k_f$	0.15												
$k_f$	0.14												
$k_f$	0.31												
$k_{fmax}$	0.31												
		Switching on without specification (to the primary energy carrier)											
		Most unfavorable case when switching between generator levels											
		Switching on during nominal conditions (of the primary energy carrier)											
		Switching off during normal output											
		Worst value of all switching operations											
Flicker		Angle of network impedance $\Psi_k$ :	32°										
		Long-term flicker strength $P_{fl}$ :	0.17										

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Model:** HNS3000TL-1

**E.5 Test report “Network interactions” for power generation units**

**Harmonic-( for the PGU and PGS<3.68kVA/phase)**

Load current: 100 %				
Ordinal number	Current (%) L1	Current (%) L2	Current (%) L3	Limit (%)
0	0.08	-	-	0.5% I
1	--	-	-	--
2	1.513	-	-	1.08
3	1.959	-	-	2.3
4	0.345	-	-	0.43
5	0.628	-	-	1.14
6	0.163	-	-	0.30
7	0.450	-	-	0.77
8	0.069	-	-	0.23
9	0.139	-	-	0.40
10	0.145	-	-	0.184
11	0.254	-	-	0.33
12	0.157	-	-	0.153
13	0.487	-	-	0.21
14	0.108	-	-	0.131
15	0.390	-	-	0.15
16	0.131	-	-	0.115
17	0.180	-	-	0.132
18	0.240	-	-	0.102
19	0.257	-	-	0.118
20	0.144	-	-	0.092
21	0.309	-	-	0.107
22	0.112	-	-	0.084
23	0.153	-	-	0.098
24	0.209	-	-	0.077
25	0.350	-	-	0.09
26	0.188	-	-	0.071
27	0.220	-	-	0.083
28	0.082	-	-	0.066
29	0.132	-	-	0.078
30	0.161	-	-	0.061
31	0.293	-	-	0.073
32	0.175	-	-	0.058
33	0.109	-	-	0.068
34	0.061	-	-	0.054
35	0.100	-	-	0.064
36	0.088	-	-	0.051
37	0.200	-	-	0.061
38	0.108	-	-	0.048
39	0.096	-	-	0.058
40	0.064	-	-	0.046
THD	2.952	-	-	5
PWHD	-	-	-	22%

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## Annex E.7 Requirements to the Test Report on the NS protection

Model: HNS3000TL-1

Extract from the test report for the NS protection "Determination of electric properties"	210403960SHA-001		
<b>Test report NS Protection</b>			
Type of NS protection: <u>Integral</u>	Further manufacturer instructions		
Software version: <u>V06</u>			
Manufacturer: <u>Afore New Energy Technology(Shanghai) Co., Ltd.</u>			
Period of measurement: <u>From 2021-04-29 to 2021-05-21</u>			
	Inverter(s)		
Protective function	Set value	Tripping value	Tripping value NS protection
Rise-in-voltage protection U >>	$1.25 * U_n$	287.8V	0.128 s
Rise-in-voltage protection U >	$1.15 * U_n$	265.0V	0.195 s
Voltage drop protection U <	$0.8 * U_n$	183.5V	2.880 s*
Voltage drop protection U <	$0.45 * U_n$	103.0V	0.289 s
Frequency decrease protection f <	47.5Hz	47.48Hz	0.192 s
Frequency increase protection f >	51.5Hz	51.52Hz	0.196 s
<p><sup>a</sup> The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch.</p> <p>When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.</p> <p>The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms</p> <p>* Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p>			
<input checked="" type="checkbox"/> <b>For integrated NS protection</b>			
Assigned to power generation unit of type	Grid-connected PV inverter		
Type integrated interface switch	Power Relay		
Response time of interface switch for integrated NS protection	12ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			
NOTE1: $U_n=230V$			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

### Annex E.5 Test report “Network interactions” for power generation units

Model: HNS1000TL-1

Extract from the test report on the certificate of units		210403960SHA-001		
Type of installation:	Grid-connected PV inverter	Manufacturer 's data		
Installation manufacturer:	Afore New Energy Technology(Shanghai) Co., Ltd.	Type of installation: PV Grid-connected PV inverter		
		Power of normal output in nominal conditions):1000 W		
		Rating voltage: 230 V		
Period of measurement:		From 2021-04-29 to 2021-05-21		
		Maximum active Power $P_{E_{max}}$ 3037 W	Maximum reactive Power $S_{E_{max}}$ 3052 VA	
		Switching actions	The limit of $k_{i_{max}}$ is 1.0	
		Switching on without specification (to the primary energy carrier) $k_i$		0.15
		Most unfavorable case when switching between generator levels $k_i$		0.15
		Switching on during nominal conditions (of the primary energy carrier) $k_i$		0.14
		Switching off during normal output $k_i$		0.31
		Worst value of all switching operations $k_{i_{max}}$	0.31	
Flicker		Angle of network impedance $\psi_k$ :	32°	
		Long-term flicker strength $P_{it}$ :	0.17	

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Model: HNS1000TL-1**

**E.5 Test report "Network interactions" for power generation units**

**Harmonic-( for the PGU and PGS<3.68kVA/phase)**

Load current: 100 %				
Ordinal number	Current (%) L1	Current (%) L2	Current (%) L3	Limit (%)
0	0.08	-	-	0.5% I
1	--	-	-	--
2	1.513	-	-	1.08
3	1.959	-	-	2.3
4	0.345	-	-	0.43
5	0.628	-	-	1.14
6	0.163	-	-	0.30
7	0.450	-	-	0.77
8	0.069	-	-	0.23
9	0.139	-	-	0.40
10	0.145	-	-	0.184
11	0.254	-	-	0.33
12	0.157	-	-	0.153
13	0.487	-	-	0.21
14	0.108	-	-	0.131
15	0.390	-	-	0.15
16	0.131	-	-	0.115
17	0.180	-	-	0.132
18	0.240	-	-	0.102
19	0.257	-	-	0.118
20	0.144	-	-	0.092
21	0.309	-	-	0.107
22	0.112	-	-	0.084
23	0.153	-	-	0.098
24	0.209	-	-	0.077
25	0.350	-	-	0.09
26	0.188	-	-	0.071
27	0.220	-	-	0.083
28	0.082	-	-	0.066
29	0.132	-	-	0.078
30	0.161	-	-	0.061
31	0.293	-	-	0.073
32	0.175	-	-	0.058
33	0.109	-	-	0.068
34	0.061	-	-	0.054
35	0.100	-	-	0.064
36	0.088	-	-	0.051
37	0.200	-	-	0.061
38	0.108	-	-	0.048
39	0.096	-	-	0.058
40	0.064	-	-	0.046
THD	2.952	-	-	5
PWHD	-	-	-	22%

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## Annex E.7 Requirements to the Test Report on the NS protection

Model: HNS1000TL-1

Extract from the test report for the NS protection "Determination of electric properties"	210403960SHA-001		
<b>Test report NS Protection</b>			
Type of NS protection: <u>Integral</u>	Further manufacturer instructions		
Software version: <u>V06</u>			
Manufacturer: <u>Afore New Energy Technology(Shanghai) Co., Ltd.</u>			
Period of measurement: <u>From 2021-04-29 to 2021-05-21</u>			
	Inverter(s)		
Protective function	Set value	Tripping value	Tripping value NS protection
Rise-in-voltage protection U >>	$1.25 * U_n$	287.8V	0.128 s
Rise-in-voltage protection U >	$1.15 * U_n$	265.0V	0.195 s
Voltage drop protection U <	$0.8 * U_n$	183.5V	2.880 s*
Voltage drop protection U <	$0.45 * U_n$	103.0V	0.289 s
Frequency decrease protection f <	47.5Hz	47.48Hz	0.192 s
Frequency increase protection f >	51.5Hz	51.52Hz	0.196 s
<p><sup>a</sup> The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch. When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above. The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms * Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p>			
<input checked="" type="checkbox"/> <b>For integrated NS protection</b>			
Assigned to power generation unit of type	Grid-connected PV inverter		
Type integrated interface switch	Power Relay		
Response time of interface switch for integrated NS protection	12ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			
NOTE1: $U_n=230V$			

Signature



Name: Jonny Jing

Position: Manager

Date: 2021-05-21

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.