

# Test Verification of Conformity

Verification Number: 200601510SHA-V2

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Afore New Energy Technology (Shanghai)Co., Ltd. Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China 201114
Product Description:	PV Grid interconnected inverter
Ratings & Principle Characteristics:	See Appendix(Specifications table)
Models/Type References:	See Appendix(Specifications table)
Brand Name:	Afore
Relevant Standards:	VDE-AR-N 4105:2018 conjunction with DIN VDE V 0124-100 :2020
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2020-06-01 to 2020-07-12
Test Report Number(s):	200601510SHA-002
Additional information in Appendix.	

---

## Signature



**Name: Jonny Jing**  
**Position: Manager**  
**Date: 2020-11-23**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200601510SHA-V2

Manufacturer: Same as applicant

Specifications table				
Model	BNT036KTL	BNT040KTL	BNT050KTL	BNT060KTL
<b>Input:</b>				
Vmax PV (Vdc)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	45 x 2	50 x 2	45 x 3	50 x 3
Number MPP trackers	2	2	3	3
Number input strings	4/4	4/4	4/4/4	4/4/4
Max. PV input current(A)	36 x 2	40 x 2	36 x 3	40 x 3
MPPT voltage range (Vdc)	200-950	200-950	200-950	200-950
Vdc range @ full power (Vdc)	500-850	500-850	500-950	500-950
<b>Output</b>				
Normal Voltage(V)	3 $\phi$ /N/PE 400Vac			
Frequency (Hz)	50 Hz			
Current (normal) (A)	52.2	58	72.5	87
Current (Max. continuous) (A)	56	61	75	90
Power rating (W)	36000	40000	50000	60000
Power Rating (VA)	36000	40000	50000	60000
Power factor /rated	1(-0.8~0.8)	1(-0.8~0.8)	1(-0.8~0.8)	1(-0.8~0.8)
<b>others</b>				
Protective class	Class I			
Ingress protection (IP)	IP 65			
Temperature (°C)	-25°C to +60°C (up 45°C derating)			
Inverter Isolation	<input checked="" type="checkbox"/> Non-isolated <input type="checkbox"/> High frequency isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Weight (kg)	66			
Dimensions (WxHxD) (mm)	630 x 850 x 306			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

#### Annex E4: Verification of Conformity for power generation units

<b>Verification of Conformity for power generation units</b>	No: 200601510SHA-V2		
<b>Manufacturer</b>	Afore New Energy Technology (Shanghai)Co., Ltd. Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China 201114		
<b>Type power generation unit</b>	PV Grid interconnected inverter		
<b>Model</b>	BNT036KTL, BNT040KTL, BNT050KTL, BNT060KTL		
<b>Assessment values</b>	<b>Max. active power P<sub>E</sub>max (W)</b>	36109	BNT036KTL
		40015	BNT040KTL
		50000	BNT050KTL
		60084	BNT060KTL
	<b>Max. apparent power S<sub>E</sub>max (VA)</b>	36283	BNT036KTL
		40377	BNT040KTL
		50300	BNT050KTL
		60181	BNT060KTL
	<b>Rated voltage</b>	3/N/PE~ 400Vac	
<b>Network connection rules</b>	<b>VDE-AR-N 4105 "Power generation systems connected to the low-voltage network"</b> Technical minimum requirements for connection and parallel operation of power generation systems connected to the low voltage network		
<b>Firmware version</b>	DSP TP2.03		
The above mentioned power generation unit meets the requirements of VDE-AR-N 4105.			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

### Annex E.5 Test report “Network interactions” for power generation units

Model: BNT036KTL

Extract from the test report on the certificate of units		200601510SHA-002		
Type of installation:	PV Grid-interactive inverter	Manufacturer 's data		
Installation manufacturer:	Afore New Energy Technology(Shanghai) Co., Ltd.	Type of installation: PV Grid interconnected inverter		
		Power of normal output in nominal conditions):36000 W		
		Rating voltage: 400 V		
Period of measurement:	From 2020-06-01 to 2020-07-12			
		Maximum active Power $P_{E_{max}}$ 36109 W	Maximum reactive Power $S_{E_{max}}$ 36283 VA	
		Switching actions	The limit of $k_{i_{max}}$ is 1.0	
		Switching on without specification (to the primary energy carrier) $k_i$		0.15
		Most unfavorable case when switching between generator levels $k_i$		0.15
		Switching on during nominal conditions (of the primary energy carrier) $k_i$		0.15
		Switching off during normal output $k_i$		0.31
		Worst value of all switching operations $k_{i_{max}}$	0.31	
Flicker	Angle of network impedance $\Psi_k$ :		32°	
	Long-term flicker strength $P_{It}$ :		0.15, 0.19, 0.25	

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Model: BNT036KTL**

**E.5 Test report “Network interactions” for power generation units**

**Harmonic-( for the PGU and PGS>3.68kVA/phase)**

Load current: 100 %				
Ordinal number	Current (%) L1	Current (%) L2	Current (%) L3	Limit (%)
0	0.080	0.200	0.050	0.5% I
1	--	--	--	--
2	0.498	0.579	0.636	8%
3	0.241	0.105	0.226	Not stated
4	0.124	0.160	0.104	4%
5	1.205	1.019	1.147	10.7%
6	0.080	0.099	0.100	2.67%
7	0.403	0.421	0.340	7.2%
8	0.053	0.083	0.081	2%
9	0.070	0.046	0.086	Not stated
10	0.090	0.072	0.048	1.6%
11	0.139	0.141	0.114	3.1%
12	0.038	0.042	0.055	1.33%
13	0.196	0.143	0.120	2%
14	0.041	0.044	0.034	-
15	0.055	0.050	0.090	-
16	0.032	0.042	0.036	-
17	0.121	0.197	0.189	-
18	0.039	0.045	0.044	-
19	0.199	0.156	0.184	-
20	0.048	0.038	0.041	-
21	0.050	0.046	0.060	-
22	0.045	0.041	0.042	-
23	0.140	0.156	0.087	-
24	0.039	0.041	0.040	-
25	0.090	0.067	0.075	-
26	0.025	0.027	0.026	-
27	0.026	0.022	0.026	-
28	0.019	0.017	0.018	-
29	0.030	0.037	0.039	-
30	0.014	0.014	0.013	-
31	0.026	0.029	0.036	-
32	0.011	0.010	0.012	-
33	0.010	0.008	0.013	-
34	0.008	0.009	0.008	-
35	0.029	0.027	0.036	-
36	0.007	0.008	0.008	-
37	0.033	0.037	0.046	-
38	0.007	0.008	0.006	-
39	0.008	0.007	0.019	-
40	0.007	0.009	0.007	-
THD	1.646%	1.522%	1.650%	13%
PWHD	0.015%	0.015%	0.015%	22%

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## Annex E.7 Requirements to the Test Report on the NS protection

Model: BNT036KTL

Extract from the test report for the NS protection "Determination of electric properties"	200601510SHA-002		
<b>Test report NS Protection</b>			
Type of NS protection: <u>Integral</u>	Further manufacturer instructions		
Software version: <u>DSP TP 2.03</u>			
Manufacturer: <u>Afore New Energy Technology(Shanghai) Co., Ltd.</u>			
Period of measurement: <u>From 2020-06-01 to 2020-07-12</u>			
	Inverter(s)		
Protective function	Set value	Tripping value	Tripping value NS protection
Rise-in-voltage protection U >>	$1.25 * U_n$	501V	165 ms
Rise-in-voltage protection U >	$1.15 * U_n$	461V	181 ms
Voltage drop protection U <	$0.8 * U_n$	322V	2 s*
Voltage drop protection U <	$0.45 * U_n$	181V	246 ms
Frequency decrease protection f <	47.5Hz	47.48Hz	185 ms
Frequency increase protection f >	51.5Hz	51.51Hz	183 ms
<p><sup>a</sup> The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch.</p> <p>When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.</p> <p>The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms</p> <p>* Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p>			
<input checked="" type="checkbox"/> <b>For integrated NS protection</b>			
Assigned to power generation unit of type	PV Grid-interactive inverter		
Type integrated interface switch	Power Relay		
Response time of interface switch for integrated NS protection	12ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			
NOTE1: Un=400V			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Annex E.5 Test report “Network interactions” for power generation units  
Model: BNT040KTL**

Extract from the test report on the certificate of units		200601510SHA-002		
Type of installation:	PV Grid-interactive inverter	Manufacturer 's data		
Installation manufacturer:	Afore New Energy Technology(Shanghai) Co., Ltd.	Type of installation: PV Grid interconnected inverter		
		Power of normal output in nominal conditions):40000 W		
		Rating voltage: 400 V		
Period of measurement:		From 2020-06-01 to 2020-07-12		
		Maximum active Power $P_{E_{max}}$ 40015 W	Maximum reactive Power $S_{E_{max}}$ 40377_VA	
		Switching actions	The limit of $k_{i_{max}}$ is 1.0	
		Switching on without specification (to the primary energy carrier) $k_i$		0.15
		Most unfavorable case when switching between generator levels $k_i$		0.15
		Switching on during nominal conditions (of the primary energy carrier) $k_i$		0.15
		Switching off during normal output $k_i$		0.31
		Worst value of all switching operations $k_{i_{max}}$	0.31	
Flicker		Angle of network impedance $\psi_k$ :	32°	
		Long-term flicker strength $P_{It}$ :	0.15, 0.19, 0.25	

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Model: BNT040KTL**

**E.5 Test report "Network interactions" for power generation units**

**Harmonic-( for the PGU and PGS>3.68kVA/phase)**

Load current: 100 %				
Ordinal number	Current (%) L1	Current (%) L2	Current (%) L3	Limit (%)
0	0.140	0.130	0.130	0.5% I
1	--	--	--	--
2	0.263	0.384	0.643	8%
3	0.176	0.099	0.130	Not stated
4	0.201	0.211	0.212	4%
5	0.579	0.592	0.543	10.7%
6	0.070	0.073	0.078	2.67%
7	0.804	0.811	0.827	7.2%
8	0.060	0.053	0.083	2%
9	0.066	0.074	0.086	Not stated
10	0.066	0.055	0.091	1.6%
11	0.799	0.767	0.755	3.1%
12	0.055	0.069	0.077	1.33%
13	1.310	1.835	1.509	2%
14	0.215	0.127	0.206	-
15	0.205	0.152	0.217	-
16	0.062	0.055	0.059	-
17	0.158	0.170	0.172	-
18	0.021	0.020	0.026	-
19	0.052	0.054	0.060	-
20	0.018	0.016	0.022	-
21	0.015	0.014	0.018	-
22	0.012	0.012	0.013	-
23	0.036	0.040	0.039	-
24	0.010	0.008	0.010	-
25	0.044	0.048	0.047	-
26	0.009	0.007	0.008	-
27	0.009	0.007	0.008	-
28	0.010	0.010	0.008	-
29	0.044	0.046	0.045	-
30	0.009	0.008	0.009	-
31	0.046	0.049	0.046	-
32	0.008	0.008	0.009	-
33	0.008	0.008	0.007	-
34	0.008	0.007	0.007	-
35	0.052	0.054	0.055	-
36	0.007	0.007	0.009	-
37	0.047	0.051	0.047	-
38	0.009	0.009	0.006	-
39	0.009	0.008	0.007	-
40	0.010	0.008	0.008	-
THD	2.211	2.629	2.395	13%
PWHD	0.015	0.013	0.015	22%

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## Annex E.7 Requirements to the Test Report on the NS protection

Model: BNT040KTL

Extract from the test report for the NS protection "Determination of electric properties"	200601510SHA-002		
<b>Test report NS Protection</b>			
Type of NS protection: <u>Integral</u>	Further manufacturer instructions		
Software version: <u>DSP TP 2.03</u>			
Manufacturer: <u>Afore New Energy Technology(Shanghai) Co., Ltd.</u>			
Period of measurement: <u>From 2020-06-01 to 2020-07-12</u>			
	Inverter(s)		
Protective function	Set value	Tripping value	Tripping value NS protection
Rise-in-voltage protection U >>	$1.25 * U_n$	501V	165 ms
Rise-in-voltage protection U >	$1.15 * U_n$	461V	181 ms
Voltage drop protection U <	$0.8 * U_n$	322V	2 s*
Voltage drop protection U <	$0.45 * U_n$	181V	246 ms
Frequency decrease protection f <	47.5Hz	47.48Hz	185 ms
Frequency increase protection f >	51.5Hz	51.51Hz	183 ms
<p><sup>a</sup> The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch.</p> <p>When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.</p> <p>The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms</p> <p>* Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p>			
<input checked="" type="checkbox"/> <b>For integrated NS protection</b>			
Assigned to power generation unit of type	PV Grid-interactive inverter		
Type integrated interface switch	Power Relay		
Response time of interface switch for integrated NS protection	12ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			
NOTE1: Un=400V			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Annex E.5 Test report “Network interactions” for power generation units  
Model: BNT050KTL**

Extract from the test report on the certificate of units		200601510SHA-002																					
Type of installation:	PV Grid-interactive inverter	Manufacturer 's data																					
Installation manufacturer:	Afore New Energy Technology(Shanghai) Co., Ltd.	Type of installation: PV Grid interconnected inverter																					
		Power of normal output in nominal conditions):50000 W																					
		Rating voltage: 400 V																					
Period of measurement:	From 2020-06-01 to 2020-07-12																						
		Maximum active Power $P_{E_{max}}$ 50000 W	Maximum reactive Power $S_{E_{max}}$ 50300 VA																				
		<table border="1"> <tr> <td>Switching actions</td> <td><math>k_i</math></td> <td>0.15</td> <td rowspan="5">The limit of <math>k_{i_{max}}</math> is 1.0</td> </tr> <tr> <td>Switching on without specification (to the primary energy carrier)</td> <td><math>k_i</math></td> <td>0.15</td> </tr> <tr> <td>Most unfavorable case when switching between generator levels</td> <td><math>k_i</math></td> <td>0.15</td> </tr> <tr> <td>Switching on during nominal conditions (of the primary energy carrier)</td> <td><math>k_i</math></td> <td>0.31</td> </tr> <tr> <td>Switching off during normal output</td> <td><math>k_i</math></td> <td>0.31</td> </tr> <tr> <td>Worst value of all switching operations</td> <td><math>k_{i_{max}}</math></td> <td>0.31</td> <td></td> </tr> </table>		Switching actions	$k_i$	0.15	The limit of $k_{i_{max}}$ is 1.0	Switching on without specification (to the primary energy carrier)	$k_i$	0.15	Most unfavorable case when switching between generator levels	$k_i$	0.15	Switching on during nominal conditions (of the primary energy carrier)	$k_i$	0.31	Switching off during normal output	$k_i$	0.31	Worst value of all switching operations	$k_{i_{max}}$	0.31	
Switching actions	$k_i$	0.15	The limit of $k_{i_{max}}$ is 1.0																				
Switching on without specification (to the primary energy carrier)	$k_i$	0.15																					
Most unfavorable case when switching between generator levels	$k_i$	0.15																					
Switching on during nominal conditions (of the primary energy carrier)	$k_i$	0.31																					
Switching off during normal output	$k_i$	0.31																					
Worst value of all switching operations	$k_{i_{max}}$	0.31																					
Flicker	Angle of network impedance $\Psi_k$ :		32°																				
	Long-term flicker strength $P_{It}$ :		0.15, 0.19, 0.25																				

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Model: BNT050KTL**

**E.5 Test report "Network interactions" for power generation units**

**Harmonic-( for the PGU and PGS>3.68kVA/phase)**

Load current: 100 %				
Ordinal number	Current (%) L1	Current (%) L2	Current (%) L3	Limit (%)
0	0.120	0.080	0.060	0.5% I
1	--	--	--	--
2	0.336	0.652	0.510	8%
3	0.148	0.131	0.178	Not stated
4	0.106	0.158	0.107	4%
5	0.995	0.778	0.989	10.7%
6	0.074	0.085	0.087	2.67%
7	0.381	0.420	0.331	7.2%
8	0.054	0.071	0.063	2%
9	0.075	0.048	0.085	Not stated
10	0.066	0.066	0.044	1.6%
11	0.043	0.076	0.061	3.1%
12	0.043	0.047	0.041	1.33%
13	0.092	0.070	0.073	2%
14	0.046	0.040	0.030	-
15	0.030	0.032	0.039	-
16	0.030	0.028	0.025	-
17	0.027	0.034	0.030	-
18	0.025	0.023	0.024	-
19	0.051	0.037	0.053	-
20	0.024	0.023	0.023	-
21	0.036	0.042	0.066	-
22	0.031	0.025	0.024	-
23	0.042	0.039	0.067	-
24	0.028	0.025	0.024	-
25	0.067	0.078	0.066	-
26	0.024	0.025	0.024	-
27	0.029	0.021	0.032	-
28	0.017	0.018	0.017	-
29	0.031	0.037	0.035	-
30	0.012	0.013	0.012	-
31	0.035	0.036	0.033	-
32	0.009	0.009	0.009	-
33	0.009	0.009	0.008	-
34	0.008	0.007	0.009	-
35	0.031	0.029	0.033	-
36	0.005	0.006	0.005	-
37	0.021	0.026	0.028	-
38	0.005	0.004	0.004	-
39	0.007	0.006	0.012	-
40	0.004	0.004	0.005	-
THD	1.348	1.437	1.471	13%
PWHD	0.007	0.007	0.008	22%

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## Annex E.7 Requirements to the Test Report on the NS protection

Model: BNT050KTL

Extract from the test report for the NS protection "Determination of electric properties"	200601510SHA-002		
<b>Test report NS Protection</b>			
Type of NS protection: <u>Integral</u>	Further manufacturer instructions		
Software version: <u>DSP TP 2.03</u>			
Manufacturer: <u>Afore New Energy Technology(Shanghai) Co., Ltd.</u>			
Period of measurement: <u>From 2020-06-01 to 2020-07-12</u>			
	Inverter(s)		
Protective function	Set value	Tripping value	Tripping value NS protection
Rise-in-voltage protection U >>	$1.25 * U_n$	501V	165 ms
Rise-in-voltage protection U >	$1.15 * U_n$	461V	181 ms
Voltage drop protection U <	$0.8 * U_n$	322V	2 s*
Voltage drop protection U <	$0.45 * U_n$	181V	246 ms
Frequency decrease protection f <	47.5Hz	47.48Hz	185 ms
Frequency increase protection f >	51.5Hz	51.51Hz	183 ms
<p><sup>a</sup> The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch.</p> <p>When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.</p> <p>The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms</p> <p>* Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p>			
<input checked="" type="checkbox"/> <b>For integrated NS protection</b>			
Assigned to power generation unit of type	PV Grid-interactive inverter		
Type integrated interface switch	Power Relay		
Response time of interface switch for integrated NS protection	12ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			
NOTE1: Un=400V			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

### Annex E.5 Test report “Network interactions” for power generation units

Model: BNT060KTL

Extract from the test report on the certificate of units		200601510SHA-002	
Type of installation:	Grid-connected Micro Inverter	Manufacturer 's data	
Installation manufacturer:	Afore New Energy Technology (Shanghai) Co., Ltd.	Type of installation: PV Grid interconnected inverter	
		Power of normal output in nominal conditions): 60000W	
		Rating voltage: 400 V	
Period of measurement:	From 2020-06-01 to 2020-07-12		
Maximum active Power $P_{E_{max}}$	60084 W	Maximum reactive Power $S_{E_{max}}$	600181 VA
Switching actions			The limit of $k_{i_{max}}$ is 1.0
Switching on without specification (to the primary energy carrier)	$k_i$	0.15	
Most unfavorable case when switching between generator levels	$k_i$	0.15	
Switching on during nominal conditions (of the primary energy carrier)	$k_i$	0.15	
Switching off during normal output	$k_i$	0.31	
Worst value of all switching operations	$k_{i_{max}}$	0.31	
Flicker	Angle of network impedance $\Psi_k$ :	32°	
	Long-term flicker strength $P_{lt}$ :	0.15, 0.19, 0.25	

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Model: BNT060KTL**

**F.3 Requirements to the Test Report on Generation Units**

**Harmonic-( for the PGU and PGS≤3.68kVA/phase)**

Load current: 100 %				
Ordinal number	Current (%) L1	Current (%) L2	Current (%) L3	Limit (%)
0	0.070	0.150	0.190	0.5% I
1	--	--	--	--
2	0.398	0.569	0.571	8%
3	0.203	0.131	0.197	Not stated
4	0.127	0.152	0.105	4%
5	1.001	0.830	0.969	10.7%
6	0.090	0.081	0.092	2.67%
7	0.353	0.364	0.303	7.2%
8	0.055	0.072	0.066	2%
9	0.062	0.053	0.074	Not stated
10	0.083	0.065	0.046	1.6%
11	0.105	0.103	0.091	3.1%
12	0.038	0.044	0.055	1.33%
13	0.135	0.111	0.067	2%
14	0.037	0.041	0.034	-
15	0.052	0.039	0.080	-
16	0.033	0.039	0.031	-
17	0.084	0.152	0.147	-
18	0.034	0.037	0.040	-
19	0.145	0.116	0.141	-
20	0.046	0.038	0.037	-
21	0.040	0.043	0.046	-
22	0.043	0.036	0.039	-
23	0.089	0.095	0.043	-
24	0.039	0.036	0.041	-
25	0.120	0.081	0.107	-
26	0.029	0.028	0.030	-
27	0.027	0.027	0.024	-
28	0.021	0.018	0.022	-
29	0.030	0.033	0.046	-
30	0.014	0.014	0.013	-
31	0.015	0.024	0.028	-
32	0.011	0.010	0.011	-
33	0.009	0.008	0.009	-
34	0.008	0.008	0.009	-
35	0.029	0.025	0.032	-
36	0.007	0.006	0.006	-
37	0.023	0.030	0.033	-
38	0.007	0.006	0.006	-
39	0.007	0.006	0.014	-
40	0.006	0.006	0.006	-
THD	1.428%	1.376%	1.458%	13%
PWHD	0.012%	0.012%	0.013%	22%

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## Annex E.7 Requirements to the Test Report on the NS protection

Model: BNT060KTL

Extract from the test report for the NS protection "Determination of electric properties"	200601510SHA-002		
<b>Test report NS Protection</b>			
Type of NS protection: <u>Integral</u>	Further manufacturer instructions		
Software version: <u>DSP TP 2.03</u>			
Manufacturer: <u>Afore New Energy Technology(Shanghai) Co., Ltd.</u>			
Period of measurement: <u>From 2020-06-01 to 2020-07-12</u>			
	Inverter(s)		
Protective function	Set value	Tripping value	Tripping value NS protection
Rise-in-voltage protection U >>	$1.25 * U_n$	501V	165 ms
Rise-in-voltage protection U >	$1.15 * U_n$	461V	181 ms
Voltage drop protection U <	$0.8 * U_n$	322V	2 s*
Voltage drop protection U <	$0.45 * U_n$	181V	246 ms
Frequency decrease protection f <	47.5Hz	47.48Hz	185 ms
Frequency increase protection f >	51.5Hz	51.51Hz	183 ms
<p><sup>a</sup> The tripping time includes the period from the limit value violation U/f until the tripping signal to the interface switch.</p> <p>When planning the power generation system, the response time of the interface switch shall be added to the maximum time value obtained as indicated above.</p> <p>The disconnection time (sum of tripping time of the NS protection plus response time of the interface switch) shall not exceed 200 ms</p> <p>* Longest disconnection of the rise-in-voltage protection as a moving 10-minute-average.</p>			
<input checked="" type="checkbox"/> <b>For integrated NS protection</b>			
Assigned to power generation unit of type	PV Grid-interactive inverter		
Type integrated interface switch	Power Relay		
Response time of interface switch for integrated NS protection	12ms		
Verification of the entire functional chain "integrated NS protection – interface switch" has resulted in successful disconnection.			
NOTE1: Un=400V			

Signature



Name: Jonny Jing

Position: Manager

Date: 2020-11-23

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.