

Certificate of Conformity

Certificate Number: CN-PV-230261

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Afore New Energy Technology (Shanghai) Co., Ltd. Build No.7, 333 Wanfang Road, Minhang District, Shanghai. China. 201112
Product:	Hybrid Inverter
Ratings & Principle Characteristics:	See appendix of Certificate of Conformity
Model:	AF1K-SL-1, AF1.5K-SL-1, AF2K-SL-1, AF2.5K-SL-1, AF3K-SL-1, AF3.6K-SL-1, AF3K-SL, AF3.6K-SL, AF4K-SL, AF4.6K-SL, AF5K-SL, AF5.5K-SL, AF6K-SL, AF1K-SL-0, AF1.5K-SL-0, AF2K-SL-0, AF2.5K-SL-0, AF3K-SL-0, AF3.6KSL-0, AF4K-SL-0, AF4.6K-SL-0, AF5K-SL-0, AF5.5K-SL-0, AF6K-SL-0
Brand Name<s>:	Afore
Product Complies with:	NRS 097-2-1:2017
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2 nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	230500129SHA-001

Additional information in Appendix.



Signature

Certification Manager: Qiao Qiao
Date: 25 May 2023



PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230261

Ratings & Principal Characteristics:

Remark: Below model compliance with NRS 097-2-1:2017 Edition 2.1

Specifications table					
Model	AF1K-SL-1	AF1.5K-SL-1	AF2K-SL-1	AF2.5K-SL-1	AF3K-SL-1
PV input					
P _{pv} Max(W)	1500	2300	3000	3800	4500
V _{max} PV (Vdc) (absolute Max.)	550	550	550	550	550
I _{sc} PV (absolute Max.) (A)	26	26	26	26	26
Number MPP trackers	1	1	1	1	1
Number input strings	1	1	1	1	1
Max. PV input current / strings (A)	18.5	18.5	18.5	18.5	18.5
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	80-500	90-500	120-500	150-500	170-500
Battery (charge/discharge)					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)				
Max charge/discharge Current(A)	25	40	50	63	80
Max charge/discharge Power(W)	1000	1500	2000	2500	3000
AC Grid (input and output)					
Normal AC Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Normal AC Current (A)	4.4	6.6	8.7	10.9	13.1
Max. cont. input/output current (A)	5	7	10	12	14
Rated Power(W)	1000	1500	2000	2500	3000
Rated Apparent Power (VA)	1000	1500	2000	2500	3000
Max. cont. Power (W)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor (adjustable)	1.0(-0.8~ +0.8)				
AC Load output (stand alone)					
Normal Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Nominal Current(A)	4.4	6.6	8.7	10.9	13.1
Max. cont. current (A)	5	7	10	12	14
Max. cont. Power (W)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor	1.0				
Others					
Ingress protection (IP)	IP65				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	Non-isolated (PV - AC - BAT)				
Overvoltage category	OVC III (AC Main), OVC II (PV)				
Firmware Version	V06				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230261

Ratings & Principal Characteristics:

Remark: Below model compliance with NRS 097-2-1:2017 Edition 2.1

Specifications table				
Model	AF3.6K-SL-1	AF3K-SL	AF3.6K-SL	AF4K-SL
PV input				
P _{pv} Max(W)	5400	4500	5400	6000
V _{max} PV (Vdc) (absolute Max.)	550	550	550	550
I _{sc} PV (absolute Max.) (A)	26	26 x 2	26 x 2	26 x 2
Number MPP trackers	1	2	2	2
Number input strings	1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	210-500	90-500	110-500	120-500
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	80
Max charge/discharge Power(W)	3600	3000	3600	4000
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	15.7	13.1	15.7	17.4
Max. cont. input/output current (A)	17	14	17	19
Rated Power(W)	3600	3000	3600	4000
Rated Apparent Power (VA)	3600	3000	3600	4000
Max. cont. Power (W)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor (adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current(A)	15.7	13.1	15.7	17.4
Max. cont. current (A)	17	14	17	19
Max. cont. Power (W)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware Version	V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230261

Ratings & Principal Characteristics:

Remark: Below model compliance with NRS 097-2-1:2017 Edition 2.1

Specifications table				
Model	AF4.6K-SL	AF5K-SL	AF5.5K-SL	AF6K-SL
PV input				
P _{pv} Max(W)	6900	7500	8300	9000
V _{max} PV (Vdc) (absolute Max.)	550	550	550	550
I _{sc} PV (absolute Max.) (A)	26 x 2	26 x 2	26 x 2	26 x 2
Number MPP trackers	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2
Number input strings	2	2	2	2
Max. PV input current / strings (A)	1/1	1/1	1/1	1/1
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	130-500	150-500	160-500	170-500
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	80
Max charge/discharge Power(W)	4600	4800	4800	4800
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	20	21.8	24	26.1
Max. cont. input/output current (A)	22	23	26	28
Rated Power(W)	4600	5000	5500	6000
Rated Apparent Power (VA)	4600	5000	5500	6000
Max. cont. Power (W)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor (adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current(A)	20	21.8	24	26.1
Max. cont. current (A)	22	23	26	28
Max. cont. Power (W)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware Version	V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230261

Ratings & Principal Characteristics:

Remark: Below model compliance with NRS 097-2-1:2017 Edition 2.1

Specifications table				
Model	AF1K-SL-0	AF1.5K-SL-0	AF2K-SL-0	AF2.5K-SL-0
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	25	40	50	63
Max charge/discharge Power(W)	1000	1500	2000	2500
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	6.6	8.7	10.9
Max. cont. input/output current (A)	5	7	10	12
Normal Power (W)	1000	1500	2000	2500
Rated Apparent Power (VA)	1000	1500	2000	2500
Max. cont. input/output Power (W)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	4.4	6.6	8.7	10.9
Max. cont. current (A)	5	7	10	12
Max. cont. Power (W)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overtoltage category	OVC III (AC Main)			
Firmware Version	V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230261

Ratings & Principal Characteristics:

Remark: Below model compliance with NRS 097-2-1:2017 Edition 2.1

Specifications table				
Model	AF3K-SL-0	AF3.6K-SL-0	AF4K-SL-0	AF4.6K-SL-0
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	80
Max charge/discharge Power(W)	3000	3600	4000	4600
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	13.1	15.7	17.4	20
Max. cont. input/output current (A)	14	17	19	22
Normal Power (W)	3000	3600	4000	4600
Rated Apparent Power (VA)	3000	3600	4000	4600
Max. cont. input/output Power (W)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	13.1	15.7	17.4	20
Max. cont. current (A)	14	17	19	22
Max. cont. Power (W)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Oversvoltage category	OVC III (AC Main)			
Firmware Version	V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PV-230261

Ratings & Principal Characteristics:

Remark: Below model compliance with NRS 097-2-1:2017 Edition 2.1

Specifications table				
Model	AF5K-SL-0	AF5.5K-SL-0	AF6K-SL-0	
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	100	120	120	
Max charge/discharge Power(W)	5000	5500	6000	
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	21.8	24	26.1	
Max. cont. input/output current (A)	23	26	28	
Normal Power (W)	5000	5500	6000	
Rated Apparent Power (VA)	5000	5500	6000	
Max. cont. input/output Power (W)	5000	5500	6000	
Max. cont. Apparent Power (VA)	5000	5500	6000	
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	21.8	24	26.1	
Max. cont. current (A)	23	26	28	
Max. cont. Power (W)	5000	5500	6000	
Max. cont. Apparent Power (VA)	5000	5500	6000	
Power factor	1.0			
Others				
Ingress protection (IP)	IP65			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overtoltage category	OVC III (AC Main)			
Firmware Version	V06			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.