

ATTESTATION OF CONFORMITY

Issued to: Afore New Energy Technology (Shanghai) Co., Ltd.
Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China.

For the product: Hybrid Inverter

Trade name: AFORE

Type/Model: HNS3000HS, HNS3600HS, HNS4000HS, HNS4600HS,
HNS5000HS, HNS5500HS, HNS6000HS

Ratings: Rated DC Input Voltage: 360V
Nominal AC Voltage: 230V / 50 / 60Hz

Manufactured by: Afore New Energy Technology (Shanghai) Co., Ltd.
Build No.7, 333 Wanfang Road, Minhang District, Shanghai, China.

Requirements: EN 61000-6-1:2007
EN 61000-6-2:2005
EN 61000-6-3:2007+A1:2011+AC:2012
EN 61000-6-4:2007+A1:2011

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 2070284R-PV-CE-P01V01.

This Attestation implies that the examined types are in accordance with the standard.

The examination has been carried out on one single specimen or several specimens of the product; submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 26 August 2020

Number: 3181243.95AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

