

# Test Verification of Conformity

Verification Number: 200101582SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

Applicant Name & Address:	Afore New Energy Technology (Shanghai) Co., Ltd. Building No.7, 333 Wanfang Road, Minhang District, Shanghai, China 201112
Product Description:	Utility Interactive Inverter (Non-Isolated Inverter)
Ratings & Principle Characteristics:	See appendix for details
Models/Type References:	BNT followed by 025, 030, 036, 040, 050 or 060; followed by KTL.
Brand Name:	Afore
Relevant Standards:	CFR 47 Part 15 (2019) ANSI C63.4 (2014)
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of test:	2020-01-06 ~ 2020-06-01
Test Report Number(s):	200101582SHA-001

Signature



**Name:** Jonny Jing  
**Position:** Manager  
**Date:** 2020-06-05

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 200101582SHA-V1.

Manufacturing Site Name & Address:	Afore New Energy Technology (Shanghai) Co., Ltd. Building No.7, 333 Wanfang Road, Minhang District, Shanghai, China 201112
------------------------------------	--

### Rating table:

Rating table			
Model	BNT025kTL	BNT030kTL	BNT036kTL
<b>PV Input:</b>			
Vmax PV (Vdc)	1000		
Isc PV (absolute Max.) (A) / MPPT	34*3	34*3	68*2
Number MPP trackers	3	3	2
Number input strings	2/2/2	2/2/2	4/4
Max. PV input current(A)	22*3	22*3	44*2
Nominal input power (kW)	26	31	37.5
Operating range (Vdc)	200 - 950		
Vdc range @ full power (Vdc)	540 - 850		
<b>AC Output</b>			
Normal Voltage (Vac)	480Vac 3Φ/PE		
Frequency (Hz)	60		
Current (Max. continuous) (A)	34	40	48
Power rating (kW)	25	30	36
Power Rating (kVA)	25	30	36
Power factor/rated (adjustable)	1 (-0.8 to +0.8)		
<b>others</b>			
Ingress protection (IP)	NEMA 4X		
Temperature (°C)	-13 to +140 / - 25 to +60 (Derating 45)		
Inverter Isolation	■ Non-isolated    □ High frequency isolated		
Overvoltage category	OVC II (PV), OVC III (AC Main)		

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Rating table			
Model	BNT040kTL	BNT050kTL	BNT060kTL
<b>PV Input:</b>			
Vmax PV (Vdc)	1000		
Isc PV (absolute Max.) (A) / MPPT	68*2	68*3	68*3
Number MPP trackers	2	3	3
Number input strings	4/4	4/4/4	4/4/4
Max. PV input current(A)	44*2	44*3	44*3
Nominal input power (kW)	42	52	62
Operating range (Vdc)	200 - 950		
Vdc range @ full power (Vdc)	540 - 850		
<b>AC Output</b>			
Normal Voltage (Vac)	480Vac 3Φ/PE		
Frequency (Hz)	60		
Current (Max. continuous) (A)	53	66.2	79.4
Power rating (kW)	40	50	60
Power Rating (kVA)	40	50	60
Power factor /rated (adjustable)	1 (-0.8 to +0.8)		
<b>others</b>			
Ingress protection (IP)	NEMA 4X		
Temperature (℃)	-13 to +140 / - 25 to +60 (Derating 45)		
Inverter Isolation	■ Non-isolated □High frequency isolated		
Overvoltage category	OVC II (PV), OVC III (AC Main)		

Signature



Name: Jonny Jing  
Position: Manager  
Date: 2020-06-05

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.