

# Certificate of Conformity

Certificate Number: CN-PVES-250309

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Afore New Energy Technology (Shanghai) Co., Ltd.  Building 7, No.333 Wanfang Rd, Minhang District, Shanghai, China. 201112
<b>Product:</b>	Grid-interactive inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	AF*-SL-0 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) AF*-SL-1 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K) AF*-SL (*= 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) AF*-SLP (*= 4K, 4.6K, 5K, 5.5K, 6K) AF*-ASL-0 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) AF*-ASL-1 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K) AF*-ASL (*= 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K)
<b>Brand Name&lt;s&gt;:</b>	Afore
<b>Product Complies with:</b>	EN 50549-1:2019 conjunction with EN 50549-10:2022
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China  Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	2504B0879SHA-001

Additional information in Appendix.

Signature

Certification Manager: Qiao Qiao  
Date: 08 August 2025



01886

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250309

Specifications table					
Model	AF1K-SL-1	AF1.5K-SL-1	AF2K-SL-1	AF2.5K-SL-1	AF3K-SL-1
	AF1K-ASL-1	AF1.5K-ASL-1	AF2K-ASL-1	AF2.5K-ASL-1	AF3K-ASL-1
PV input					
P pv Max(W)	1500	2300	3000	3800	4500
Vmax PV (Vdc) (absolute Max.)	550	550	550	550	550
Isc PV (absolute Max.) (A)	26	26	26	26	26
Number MPP trackers	1	1	1	1	1
Number input strings	1	1	1	1	1
Max. PV input current / strings (A)	18.5	18.5	18.5	18.5	18.5
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	80-500	90-500	120-500	150-500	170-500
Battery (charge/discharge)					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)				
Max charge/discharge Current(A)	25	40	50	63	80
Max charge/discharge Power(W)	1000	1500	2000	2500	3000
AC Grid (input and output)					
Normal AC Voltage (VAC)	L/N/PE, 220Vac, 230Vac				
Frequency (Hz)	50 / 60				
Normal AC Current (A)	4.4	6.6	8.7	10.9	13.1
Max. cont. input/output current (A)	5	7	10	12	14
Rated Power(W)	1000	1500	2000	2500	3000
Rated Apparent Power (VA)	1000	1500	2000	2500	3000
Max. cont. Power (W)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor (adjustable)	1.0( -0.8~ +0.8)				
AC Load output (stand alone)					
Normal Voltage (VAC)	L/N/PE, 220Vac, 230Vac				
Frequency (Hz)	50 / 60				
Nominal Current(A)	4.4	6.6	8.7	10.9	13.1
Max. cont. current (A)	5	7	10	12	14
Max. cont. Power (W)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor	1.0				
Others					
Ingress protection (IP)	IP66				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating45°C)				
Inverter Isolation	Non-isolated (PV - AC - BAT)				
Overvoltage category	OVC III (AC Main), OVC II (DC)				
Firmware version	1.01				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250309

Specifications table				
Model	AF3.6K-SL-1	AF3K-SL	AF3.6K-SL	AF4K-SL
	AF3.6K-ASL-1	AF3K-ASL	AF3.6K-ASL	
PV input				
P pv Max(W)	5400	4500	5400	6000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550
Isc PV (absolute Max.) (A)	26	26 x 2	26 x 2	26 x 2
Number MPP trackers	1	2	2	2
Number input strings	1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	210-500	90-500	110-500	120-500
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	80
Max charge/discharge Power(W)	3600	3000	3600	4000
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Normal AC Current (A)	15.7	13.1	15.7	17.4
Max. cont. input/output current (A)	17	14	17	19
Rated Power(W)	3600	3000	3600	4000
Rated Apparent Power (VA)	3600	3000	3600	4000
Max. cont. Power (W)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor (adjustable)	1.0( -0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Nominal Current(A)	15.7	13.1	15.7	17.4
Max. cont. current (A)	17	14	17	19
Max. cont. Power (W)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250309

Specifications table				
Model	AF4.6K-SL	AF5K-SL	AF5.5K-SL	AF6K-SL
PV input				
P pv Max(W)	6900	7500	8300	9000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550
Isc PV (absolute Max.) (A)	26 x 2	26 x 2	26 x 2	26 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	130-500	150-500	160-500	170-500
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	80
Max charge/discharge Power(W)	4600	4800	4800	4800
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Normal AC Current (A)	20	21.8	24	26.1
Max. cont. input/output current (A)	22	23	26	28
Rated Power(W)	4600	5000	5500	6000
Rated Apparent Power (VA)	4600	5000	5500	6000
Max. cont. Power (W)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor (adjustable)	1.0( -0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Nominal Current(A)	20	21.8	24	26.1
Max. cont. current (A)	22	23	26	28
Max. cont. Power (W)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250309

Specifications table					
Model	AF4K-SLP	AF4.6K-SLP	AF5K-SLP	AF5.5K-SLP	AF6K-SLP
	AF4K-ASL	AF4.6K-ASL	AF5K-ASL	AF5.5K-ASL	AF6K-ASL
PV input					
P pv Max(W)	6000	6900	7500	8300	9000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550	550
Isc PV (absolute Max.) (A)	26 x 2	26 x 2	26 x 2	26 x 2	26 x 2
Number MPP trackers	2	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500	80-500
Vdc range @ full power (Vdc)	120-500	130-500	150-500	160-500	170-500
Battery (charge/discharge)					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)				
Max charge/discharge Current(A)	120	120	120	120	120
Max charge/discharge Power(W)	4000	4600	5000	5500	6000
AC Grid (input and output)					
Normal AC Voltage (VAC)	L/N/PE, 220Vac, 230Vac				
Frequency (Hz)	50 / 60				
Normal AC Current (A)	17.4	20	21.8	24	26.1
Max. cont. input/output current (A)	19	22	23	26	28
Rated Power(W)	4000	4600	5000	5500	6000
Rated Apparent Power (VA)	4000	4600	5000	5500	6000
Max. cont. Power (W)	4000	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4000	4600	5000	5500	6000
Power factor (adjustable)	1.0( -0.8~ +0.8)				
AC Load output (stand alone)					
Normal Voltage (VAC)	L/N/PE, 220Vac, 230Vac				
Frequency (Hz)	50 / 60				
Nominal Current(A)	17.4	20	21.8	24	26.1
Max. cont. current (A)	19	22	23	26	28
Max. cont. Power (W)	4000	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4000	4600	5000	5500	6000
Power factor	1.0				
Others					
Ingress protection (IP)	IP66				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating45°C)				
Inverter Isolation	Non-isolated (PV - AC - BAT)				
Overvoltage category	OVC III (AC Main), OVC II (DC)				
Firmware version	1.01				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250309

Specifications table				
Model	AF1K-SL-0	AF1.5K-SL-0	AF2K-SL-0	AF2.5K-SL-0
	AF1K-ASL-0	AF1.5K-ASL-0	AF2K-ASL-0	AF2.5K-ASL-0
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid ect.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	25	40	50	63
Max charge/discharge Power(W)	1000	1500	2000	2500
<b>AC Grid (input and output)</b>				
Normal AC Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Normal AC Current (A)	4.4	6.6	8.7	10.9
Max. cont. input/output current (A)	5	7	10	12
Normal Power (W)	1000	1500	2000	2500
Rated Apparent Power (VA)	1000	1500	2000	2500
Max. cont. input/output Power (W)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor(adjustable)	1.0( -0.8~ +0.8)			
<b>AC Load output (stand alone)</b>				
Normal Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Nominal Current (A)	4.4	6.6	8.7	10.9
Max. cont. current (A)	5	7	10	12
Max. cont. Power (W)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor	1.0			
<b>Others</b>				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250309

Specifications table				
Model	AF3K-SL-0	AF3.6K-SL-0	AF4K-SL-0	AF4.6K-SL-0
	AF3K-ASL-0	AF3.6K-ASL-0	AF4K-ASL-0	AF4.6K-ASL-0
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	120	120
Max charge/discharge Power(W)	3000	3600	4000	4600
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Normal AC Current (A)	13.1	15.7	17.4	20
Max. cont. input/output current (A)	14	17	19	22
Normal Power (W)	3000	3600	4000	4600
Rated Apparent Power (VA)	3000	3600	4000	4600
Max. cont. input/output Power (W)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor(adjustable)	1.0( -0.8~ +0.8)			
AC Load output (stand alone)				
Normal Voltage (VAC)	L/N/PE, 220Vac, 230Vac			
Frequency (Hz)	50 / 60			
Nominal Current (A)	13.1	15.7	17.4	20
Max. cont. current (A)	14	17	19	22
Max. cont. Power (W)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250309

Specifications table			
Model	AF5K-SL-0	AF5.5K-SL-0	AF6K-SL-0
	AF5K-ASL-0	AF5.5K-ASL-0	AF6K-ASL-0
Battery (charge/discharge)			
Battery type	Li-ion/Lead-acid etc.		
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)		
Max charge/discharge Current(A)	120	120	120
Max charge/discharge Power(W)	5000	5500	6000
AC Grid (input and output)			
Normal AC Voltage (VAC)	L/N/PE, 220Vac, 230Vac		
Frequency (Hz)	50 / 60		
Normal AC Current (A)	21.8	24	26.1
Max. cont. input/output current (A)	23	26	28
Normal Power (W)	5000	5500	6000
Rated Apparent Power (VA)	5000	5500	6000
Max. cont. input/output Power (W)	5000	5500	6000
Max. cont. Apparent Power (VA)	5000	5500	6000
Power factor(adjustable)	1.0( -0.8~ +0.8)		
AC Load output (stand alone)			
Normal Voltage (VAC)	L/N/PE, 220Vac, 230Vac		
Frequency (Hz)	50 / 60		
Nominal Current (A)	21.8	24	26.1
Max. cont. current (A)	23	26	28
Max. cont. Power (W)	5000	5500	6000
Max. cont. Apparent Power (VA)	5000	5500	6000
Power factor	1.0		
Others			
Ingress protection (IP)	IP66		
Protective class	Class I		
Temperature (°C)	-25°C to +60°C (Derating45°C)		
Inverter Isolation	Non-isolated (AC-BAT)		
Overvoltage category	OVC III (AC Main), OVC II (DC)		
Firmware version	1.01		

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.