

Test Verification of Conformity

Verification Number: 2509B0691SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an a 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

This document can be used in support of a claim in meeting relevant < EU Low Voltage Directive (LVD) (2014/35/EU)>legislation and mandatory Conformity Marking. And in accordance with EU / UK law, the claim is the sole obligation of the Manufacturer/ Importer.

Applicant Name & Address:	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China. 201112
Product Description:	Hybrid inverter
Ratings & Principal Characteristics:	See Appendix(Specifications table)
Models/Type References:	AF*-ASL-1 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K) AF*-ASL (*= 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K) AF*-ASL-0 (*= 1K, 1.5K, 2K, 2.5K, 3K, 3.6K, 4K, 4.6K, 5K, 5.5K, 6K)
Brand Names:	Afore
Specification<s>/Standards:	IEC/EN 62109-1:2010 IEC/EN 62109-2:2011 EN 62477-1:2012+A11:2014+A1:2017+A12:2021
Verification Issuing Office Name & Address:	Intertek Testing Services (Shanghai FTZ) Co., Ltd. Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2024-04-17 to 2024-05-14, 2025-09-03 to 2025-11-07
Test Report Number(s):	2509B0691SHA-001/002/003
Additional information in Appendix.	

Signature



Name: Max Jin

Position: General Manager

Date: 2025-11-07

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2509B0691SHA-V1

Manufacture Name & Address: Same as applicant

Specifications table					
Model	AF1K-ASL-1	AF1.5K-ASL-1	AF2K-ASL-1	AF2.5K-ASL-1	AF3K-ASL-1
PV input					
P pv Max(W)	2000	3000	4000	5000	6000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550	550
Isc PV (absolute Max.) (A)	26	26	26	26	26
Number MPP trackers	1	1	1	1	1
Number input strings	1	1	1	1	1
Max. PV input current / strings (A)	18.5	18.5	18.5	18.5	18.5
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500	80-500
Battery (charge/discharge)					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)				
Max charge/discharge Current(A)	25	40	50	63	80
Max charge/discharge Power(W)	1000	1500	2000	2500	3000
AC Grid (input and output)					
Normal AC Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Normal AC Current (A)	4.4	6.6	8.7	10.9	13.1
Max. cont. input/output current (A)	5	7	10	12	14
Rated Power(W)	1000	1500	2000	2500	3000
Rated Apparent Power (VA)	1000	1500	2000	2500	3000
Max. cont. Power (W)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor (adjustable)	1.0(-0.8~ +0.8)				
AC Load output (stand-alone)					
Normal Voltage (VAC)	L/N/PE, 230Vac				
Frequency (Hz)	50				
Nominal Current(A)	4.4	6.6	8.7	10.9	13.1
Max. cont. current (A)	5	7	10	12	14
Max. cont. Power (W)	1000	1500	2000	2500	3000
Max. cont. Apparent Power (VA)	1000	1500	2000	2500	3000
Power factor	1.0				
Others					
Ingress protection (IP)	IP66				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating45°C)				
Inverter Isolation	Non-isolated (PV - AC - BAT)				
Overvoltage category	OVC III (AC Main), OVC II (DC)				
Firmware	1.01				

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2509B0691SHA-V1

Specifications table				
Model	AF3.6K-ASL-1	AF3K-ASL	AF3.6K-ASL	AF4K-ASL
PV input				
P pv Max(W)	7200	6000	7200	8000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550
Isc PV (absolute Max.) (A)	26	26 x 2	26 x 2	26 x 2
Number MPP trackers	1	2	2	2
Number input strings	1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	80	120
Max charge/discharge Power(W)	3600	3000	3600	4000
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	15.7	13.1	15.7	17.4
Max. cont. input/output current (A)	17	14	17	19
Rated Power(W)	3600	3000	3600	4000
Rated Apparent Power (VA)	3600	3000	3600	4000
Max. cont. Power (W)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor (adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand-alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current(A)	15.7	13.1	15.7	17.4
Max. cont. current (A)	17	14	17	19
Max. cont. Power (W)	3600	3000	3600	4000
Max. cont. Apparent Power (VA)	3600	3000	3600	4000
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware	1.01			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2509B0691SHA-V1

Specifications table				
Model	AF4.6K-ASL	AF5K-ASL	AF5.5K-ASL	AF6K-ASL
PV input				
P pv Max(W)	9200	10000	11000	12000
Vmax PV (Vdc) (absolute Max.)	550	550	550	550
Isc PV (absolute Max.) (A)	26 x 2	26 x 2	26 x 2	26 x 2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current / strings (A)	18.5 x 2	18.5 x 2	18.5 x 2	18.5 x 2
MPPT voltage range (Vdc)	80-500	80-500	80-500	80-500
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	120	120	120	120
Max charge/discharge Power(W)	4600	5000	5500	6000
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	20	21.8	24	26.1
Max. cont. input/output current (A)	22	23	26	28
Rated Power(W)	4600	5000	5500	6000
Rated Apparent Power (VA)	4600	5000	5500	6000
Max. cont. Power (W)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor (adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand-alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current(A)	20	21.8	24	26.1
Max. cont. current (A)	22	23	26	28
Max. cont. Power (W)	4600	5000	5500	6000
Max. cont. Apparent Power (VA)	4600	5000	5500	6000
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware	1.01			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2509B0691SHA-V1

Specifications table				
Model	AF1K-ASL-0	AF1.5K-ASL-0	AF2K-ASL-0	AF2.5K-ASL-0
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid ect.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	25	40	50	63
Max charge/discharge Power(W)	1000	1500	2000	2500
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	6.6	8.7	10.9
Max. cont. input/output current (A)	5	7	10	12
Normal Power (W)	1000	1500	2000	2500
Rated Apparent Power (VA)	1000	1500	2000	2500
Max. cont. input/output Power (W)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand-alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	4.4	6.6	8.7	10.9
Max. cont. current (A)	5	7	10	12
Max. cont. Power (W)	1000	1500	2000	2500
Max. cont. Apparent Power (VA)	1000	1500	2000	2500
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware	1.01			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2509B0691SHA-V1

Specifications table				
Model	AF3K-ASL-0	AF3.6K-ASL-0	AF4K-ASL-0	AF4.6K-ASL-0
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	80	80	120	120
Max charge/discharge Power(W)	3000	3600	4000	4600
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	13.1	15.7	17.4	20
Max. cont. input/output current (A)	14	17	19	22
Normal Power (W)	3000	3600	4000	4600
Rated Apparent Power (VA)	3000	3600	4000	4600
Max. cont. input/output Power (W)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand-alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	13.1	15.7	17.4	20
Max. cont. current (A)	14	17	19	22
Max. cont. Power (W)	3000	3600	4000	4600
Max. cont. Apparent Power (VA)	3000	3600	4000	4600
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware	1.01			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2509B0691SHA-V1

Specifications table				
Model	AF5K-ASL-0	AF5.5K-ASL-0	AF6K-ASL-0	
Battery (charge/discharge)				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage (Range) (Vdc)	51.2V (40-60V)			
Max charge/discharge Current(A)	120	120	120	
Max charge/discharge Power(W)	5000	5500	6000	
AC Grid (input and output)				
Normal AC Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Normal AC Current (A)	21.8	24	26.1	
Max. cont. input/output current (A)	23	26	28	
Normal Power (W)	5000	5500	6000	
Rated Apparent Power (VA)	5000	5500	6000	
Max. cont. input/output Power (W)	5000	5500	6000	
Max. cont. Apparent Power (VA)	5000	5500	6000	
Power factor(adjustable)	1.0(-0.8~ +0.8)			
AC Load output (stand-alone)				
Normal Voltage (VAC)	L/N/PE, 230Vac			
Frequency (Hz)	50			
Nominal Current (A)	21.8	24	26.1	
Max. cont. current (A)	23	26	28	
Max. cont. Power (W)	5000	5500	6000	
Max. cont. Apparent Power (VA)	5000	5500	6000	
Power factor	1.0			
Others				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated (AC-BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware	1.01			

Signature



Name: Max Jin

Position: General Manager

Date: 2025-11-07

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.