

# Certificate of Conformity

Certificate Number: CN-PVES-250496

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

<b>Applicant:</b>	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China. 201112
<b>Product:</b>	Grid-interactive inverter
<b>Ratings &amp; Principle Characteristics:</b>	See appendix of Certificate of Conformity
<b>Model:</b>	AF*-MTH (*=3K, 4K, 5K, 6K, 8K, 10K, 12K, 15K) AF*-ATH (*=3K, 4K, 5K, 6K, 8K, 10K, 12K, 15K) AF*-MTH-0 (*=3K, 4K, 5K, 6K, 8K, 10K, 12K, 15K) AF*-ATH-0 (*=3K, 4K, 5K, 6K, 8K, 10K, 12K, 15K) AF*-MTHA (*=3K, 4K, 5K, 6K, 7K) AF*-ATHA (*=3K, 4K, 5K, 6K, 7K) AF*-MTHA-0 (*=3K, 4K, 5K, 6K, 7K) AF*-ATHA-0 (*=3K, 4K, 5K, 6K, 7K)
<b>Brand Name&lt;s&gt;:</b>	Afore
<b>Product Complies with:</b>	IEC 61727:2004 IEC 62116:2014
<b>Certificate Issuing Office Name &amp; Address:</b>	Intertek Testing Services Ltd. Shanghai West Area, 2 <sup>nd</sup> Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
<b>Test Report No.&lt;s&gt;:</b>	2512B0363SHA-001

Additional information in Appendix.

Signature



**Certification Manager: Qiao Qiao**  
**Date: 29 December 2025**



01886

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250496

### Ratings & Principle Characteristics:

Specifications table				
Model	AF3K-MTH	AF4K-MTH	AF5K-MTH	AF6K-MTH
	AF3K-ATH	AF4K-ATH	AF5K-ATH	AF6K-ATH
<b>PV input</b>				
P pv Max (kW)	6	8	10	12
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	25*2	25*2	25*2	25*2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	18.5*2	18.5*2	18.5*2	18.5*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage Range (Vdc)	80-600(Field adapt battery voltage range)			
Max charge/discharge Current(A)	30	30	30	30
Max charge/discharge Power(kW)	3	4	5	6
<b>AC Grid (input and output)</b>				
Normal AC Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	5.8	7.3	8.7
Max. cont. input/output current (A)	8 / 5.3	10.5 / 7	13 / 8.5	16 / 10.5
Rated Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Max. cont. Apparent input/output Power (kVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Power factor(adjustable)	1.0(-0.8~ +0.8)			
<b>AC Load output (stand-alone)</b>				
Normal Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current (A)	4.4	5.8	7.3	8.7
Max. cont. current (A)	5.3	7	8.5	10.5
Max. cont. Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. Apparent Power (kVA)	3	4	5	6
<b>Others</b>				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware Version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250496

Specifications table				
Model	AF8K-MTH	AF10K-MTH	AF12K-MTH	AF15K-MTH
	AF8K-ATH	AF10K-ATH	AF12K-ATH	AF15K-ATH
<b>PV input</b>				
P pv Max (kW)	16	20	24	30
Vmax PV (Vdc) (absolute Max.)	1000	1000	1000	1000
Isc PV (absolute Max.) (A)	25*2	25*2	25*2	25*2
Number MPP trackers	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1
Max. PV input current (A)	18.5*2	18.5*2	18.5*2	18.5*2
MPPT voltage range (Vdc)	150-850	150-850	150-850	150-850
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage Range (Vdc)	80-600(Field adapt battery voltage range)			
Max charge/discharge Current(A)	30	30	30	30
Max charge/discharge Power(kW)	8	10	12	15
<b>AC Grid (input and output)</b>				
Normal AC Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	11.6	14.5	17.4	21.8
Max. cont. input/output current (A)	20 / 13.5	26 / 17	32 / 21.5	40.5 / 27
Rated Power (kW)	8	10	12	15
Rated Apparent Power (kVA)	8	10	12	15
Max. cont. input/output Power (kW)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5
Max. cont. Apparent input/output Power (kVA)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5
Power factor(adjustable)	1.0( -0.8~ +0.8)			
<b>AC Load output (stand-alone)</b>				
Normal Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current (A)	11.6	14.5	17.4	21.8
Max. cont. current (A)	13.5	17	21.5	27
Max. cont. Power (kW)	8	10	12	15
Rated Apparent Power (kVA)	8	10	12	15
Max. cont. Apparent Power (kVA)	8	10	12	15
<b>Others</b>				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (PV - AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware Version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250496

Specifications table				
Model	AF3K-MTH-0	AF4K-MTH-0	AF5K-MTH-0	AF6K-MTH-0
	AF3K-ATH-0	AF4K-ATH-0	AF5K-ATH-0	AF6K-ATH-0
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage Range (Vdc)	80-800(Field adapt battery voltage range)			
Max charge/discharge Current(A)	30*2	30*2	30*2	30*2
Max charge/discharge Power(kW)	3 / 3.3	4 / 4.4	5 / 5.5	6 / 6.6
<b>AC Grid (input and output)</b>				
Normal AC Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	4.4	5.8	7.3	8.7
Max. cont. input/output current (A)	8 / 5.3	10.5 / 7	13 / 8.5	16 / 10.5
Rated Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Max. cont. Apparent input/output Power (kVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6
Power factor(adjustable)	1.0( -0.8~ +0.8)			
<b>AC Load output (stand-alone)</b>				
Normal Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current (A)	4.4	5.8	7.3	8.7
Max. cont. current (A)	5.3	7	8.5	10.5
Max. cont. Power (kW)	3	4	5	6
Rated Apparent Power (kVA)	3	4	5	6
Max. cont. Apparent Power (kVA)	3	4	5	6
<b>Others</b>				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware Version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250496

Specifications table				
Model	AF8K-MTH-0	AF10K-MTH-0	AF12K-MTH-0	AF15K-MTH-0
	AF8K-ATH-0	AF10K-ATH-0	AF12K-ATH-0	AF15K-ATH-0
<b>Battery (charge/discharge)</b>				
Battery type	Li-ion/Lead-acid etc.			
Battery Normal Voltage Range (Vdc)	80-800(Field adapt battery voltage range)			
Max charge/discharge Current(A)	30*2	30*2	30*2	30*2
Max charge/discharge Power(kW)	8 / 8.8	10 / 11	12/13.2	15 / 16.5
<b>AC Grid (input and output)</b>				
Normal AC Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	11.6	14.5	17.4	21.8
Max. cont. input/output current (A)	20 / 13.5	26 / 17	32 / 21.5	40.5 / 27
Rated Power (kW)	8	10	12	15
Rated Apparent Power (kVA)	8	10	12	15
Max. cont. input/output Power (kW)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5
Max. cont. Apparent input/output Power (kVA)	12 / 8.8	15 / 11	18 / 13.2	22.5 / 16.5
Power factor(adjustable)	1.0( -0.8~ +0.8)			
<b>AC Load output (stand-alone)</b>				
Normal Voltage (Vac)	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Nominal Current (A)	11.6	14.5	17.4	21.8
Max. cont. current (A)	13.5	17	21.5	27
Max. cont. Power (kW)	8	10	12	15
Rated Apparent Power (kVA)	8	10	12	15
Max. cont. Apparent Power (kVA)	8	10	12	15
<b>Others</b>				
Ingress protection (IP)	IP66			
Protective class	Class I			
Temperature (°C)	-25°C to +60°C (Derating 45°C)			
Inverter Isolation	Non-isolated (AC - BAT)			
Overvoltage category	OVC III (AC Main), OVC II (DC)			
Firmware Version	1.01			

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250496

Specifications table					
Model	AF3K-MTHA	AF4K-MTHA	AF5K-MTHA	AF6K-MTHA	AF7K-MTHA
	AF3K-ATHA	AF4K-ATHA	AF5K-ATHA	AF6K-ATHA	AF7K-ATHA
<b>PV input</b>					
P pv Max (kW)	6	8	10	12	14
Vmax PV (Vdc) (absolute Max.)	600	600	600	600	600
Isc PV (absolute Max.) (A)	25*2	25*2	25*2	25*2	25*2
Number MPP trackers	2	2	2	2	2
Number input strings	1/1	1/1	1/1	1/1	1/1
Max. PV input current (A)	18.5*2	18.5*2	18.5*2	18.5*2	18.5*2
MPPT voltage range (Vdc)	100-550	100-550	100-550	100-550	100-550
<b>Battery (charge/discharge)</b>					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage Range (Vdc)	80-450(Field adapt battery voltage range)				
Max charge/discharge Current(A)	30	30	30	30	30
Max charge/discharge Power(kW)	3	4	5	6	7
<b>AC Grid (input and output)</b>					
Normal AC Voltage (VAC)	3P+PE/3P 133/230				
Frequency (Hz)	50				
Normal AC Current (A)	7.6	10.1	12.6	15.1	17.6
Max. cont. input/output current (A)	16 / 10.5	20 / 13.5	26 / 17	32 / 21.5	32 / 25
Rated Power (kW)	3	4	5	6	7
Rated Apparent Power (kVA)	3	4	5	6	7
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6	10.5 / 7.7
Max. cont. Apparent input/output Power (kVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6	10.5 / 7.7
Power factor(adjustable)	1.0(-0.8~ +0.8)				
<b>AC Load output (stand-alone)</b>					
Normal Voltage (VAC)	3P+PE/3P 133/230				
Frequency (Hz)	50				
Nominal Current (A)	7.6	10.1	12.6	15.1	17.6
Max. cont. current (A)	10.5	13.5	17	21.5	25
Max. cont. Power (kW)	3	4	5	6	7
Rated Apparent Power (kVA)	3	4	5	6	7
Max. cont. Apparent Power (kVA)	3	4	5	6	7
<b>Others</b>					
Ingress protection (IP)	IP66				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	Non-isolated (PV - AC - BAT)				
Overvoltage category	OVC III (AC Main), OVC II (DC)				
Firmware Version	1.01				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

## APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250496

Specifications table					
Model	AF3K-MTHA-0	AF4K-MTHA-0	AF5K-MTHA-0	AF6K-MTHA-0	AF7K-MTHA-0
	AF3K-ATHA-0	AF4K-ATHA-0	AF5K-ATHA-0	AF6K-ATHA-0	AF7K-ATHA-0
<b>Battery (charge/discharge)</b>					
Battery type	Li-ion/Lead-acid etc.				
Battery Normal Voltage Range (Vdc)	80-450(Field adapt battery voltage range)				
Max charge/discharge Current(A)	30*2	30*2	30*2	30*2	30*2
Max charge/discharge Power(kW)	3 / 3.3	4 / 4.4	5 / 5.5	6 / 6.6	7 / 7.7
<b>AC Grid (input and output)</b>					
Normal AC Voltage (VAC)	3P+PE/3P 133/230				
Frequency (Hz)	50				
Normal AC Current (A)	7.6	10.1	12.6	15.1	17.6
Max. cont. input/output current (A)	16 / 10.5	20 / 13.5	26 / 17	32 / 21.5	32 / 25
Rated Power (kW)	3	4	5	6	7
Rated Apparent Power (kVA)	3	4	5	6	7
Max. cont. input/output Power (kW)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6	10.5 / 7.7
Max. cont. Apparent input/output Power (kVA)	4.5 / 3.3	6 / 4.4	7.5 / 5.5	9 / 6.6	10.5 / 7.7
Power factor(adjustable)	1.0(-0.8~ +0.8)				
<b>AC Load output (stand-alone)</b>					
Normal Voltage (VAC)	3P+PE/3P 133/230				
Frequency (Hz)	50				
Nominal Current (A)	7.6	10.1	12.6	15.1	17.6
Max. cont. current (A)	10.5	13.5	17	21.5	25
Max. cont. Power (kW)	3	4	5	6	7
Rated Apparent Power (kVA)	3	4	5	6	7
Max. cont. Apparent Power (kVA)	3	4	5	6	7
<b>Others</b>					
Ingress protection (IP)	IP66				
Protective class	Class I				
Temperature (°C)	-25°C to +60°C (Derating 45°C)				
Inverter Isolation	Non-isolated (AC - BAT)				
Overvoltage category	OVC III (AC Main), OVC II (DC)				
Firmware Version	1.01				

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.