

Test Verification of Conformity

Verification Number: 2605B1171SHA-V1

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an accredited 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

This document can be used in support of a claim in meeting relevant EU EMC Directive(2014/30/EU) and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Applicant Name & Address:	Afore New Energy Technology (Shanghai) Co., Ltd. Building 7, No.333 Wanfang Rd, Minhang District, Shanghai. China. 201112
Product Description:	Grid-interactive inverter
Ratings & Principle Characteristics:	See Appendix for details
Models/Type References:	BNT017KTA, BNT020KTA, BNT24.99KTA, BNT025KTA, BNT29.99KTA, BNT030KTA, BNT036KTA, BNT29.99KTL, BNT030KTL, BNT036KTL, BNT040KTL, BNT050KTL, BNT060KTL.
Brand Name:	Afore
Relevant Standards/Directives:	EN IEC 61000-6-2:2019; EN IEC 61000-6-4:2019; EN IEC 61000-3-11:2019; EN IEC 61000-3-12:2011; EN IEC 62920:2017+A1:2021;
Verification Issuing Office Name & Address:	Intertek Testing Services (Shanghai FTZ) Co., Ltd. Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Date of Tests:	2023-06-28 to 2023-07-17, 2024-03-14 to 2024-03-16
Test Report Number(s):	2605B1171SHA-001


Signature

Name: Max Jin

Position: General Manager

Date: 2026-05-22

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 2605B1171SHA-V1

Specifications table				
Model	BNT29.99KTL	BNT030KTL	BNT036KTL	BNT040KTL
PV input				
P pv Max(kW)	45	45	54	60
Vmax PV (Vdc) (absolute Max.)	1100	1100	1100	1100
Isc PV (absolute Max.) (A)	48 x 2	48 x 2	48 x 3	48 x 3
Max. PV input current / strings (A)	38 x 2	38 x 2	38 x 3	38 x 3
Number MPP trackers	2	2	3	3
Number input strings	2/3	2/3	2/2/2	2/2/2
MPPT voltage range (Vdc)	200-1000	200-1000	200-1000	200-1000
AC Grid (output)				
Normal AC Voltage (V _{AC})	3P+N+PE/3P+PE 230/400			
Frequency (Hz)	50			
Normal AC Current (A)	43.5	43.5	52.2	58
Max. cont. output current (A)	48	48	60	65
Normal Power (kW)	29.99	30	36	40
Rated Apparent Power (kVA)	29.99	30	36	40
Max. cont. Power (kW)	29.99	30	36	40
Max. cont. Apparent Power (kVA)	29.99	30	36	40
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP66			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware version	1.01			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Specifications table			
Model	BNT050KTL	BNT060KTL	
PV input			
P pv Max(kW)	75	90	
Vmax PV (Vdc) (absolute Max.)	1100	1100	
Isc PV (absolute Max.) (A)	48 x 3	48 x 4	
Max. PV input current / strings (A)	40 x 3	38 x 4	
Number MPP trackers	3	4	
Number input strings	2/2/3	2/2/2/2	
MPPT voltage range (Vdc)	200-1000	200-1000	
AC Grid (output)			
Normal AC Voltage (V _{AC})	3P+N+PE/3P+PE 230/400		
Frequency (Hz)	50		
Normal AC Current (A)	72.5	87	
Max. cont. output current (A)	80	96	
Normal Power (kW)	50	60	
Rated Apparent Power (kVA)	50	60	
Max. cont. Power (kW)	50	60	
Max. cont. Apparent Power (kVA)	50	60	
Power factor(adjustable)	1.0(-0.8~ +0.8)		
Others			
Protective class	Class I		
Ingress protection (IP)	IP66		
Temperature (°C)	-25°C to +60°C (Derating45°C)		
Inverter Isolation	Non-isolated		
Overvoltage category	OVC III (AC Main), OVC II (PV)		
Firmware version	1.01		

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Specifications table				
Model	BNT017KTA	BNT020KTA	BNT24.99KTA	BNT025KTA
PV input				
P _{pv} Max(kW)	25.5	30	37.5	37.5
V _{max} PV (Vdc) (absolute Max.)	750	750	750	750
I _{sc} PV (absolute Max.) (A)	48x2	48x3	48x3	48x3
Max. PV input current / strings (A)	2	3	3	3
Number MPP trackers	2/3	2/2/2	2/2/3	2/2/3
Number input strings	38x2	38x3	40x3	40x3
MPPT voltage range (Vdc)	200-700	200-700	200-700	200-700
AC Grid (output)				
Normal AC Voltage (V _{AC})	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	42.7	50.2	62.7	62.7
Max. cont. output current (A)	48	60	80	80
Normal Power (kW)	17	20	24.99	25
Rated Apparent Power (kVA)	17	20	24.99	25
Max. cont. Power (kW)	17	20	24.99	25
Max. cont. Apparent Power (kVA)	17	20	24.99	25
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP66			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware version	1.01			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Specifications table				
Model	BNT29.99KTA	BNT030KTA	BNT036KTA	
PV input				
P _{pv} Max(kW)	45	45	54	
V _{max} PV (Vdc) (absolute Max.)	750	750	750	
I _{sc} PV (absolute Max.) (A)	48x4	48x4	48x4	
Max. PV input current / strings (A)	4	4	4	
Number MPP trackers	2/2/2/2	2/2/2/2	2/2/2/2	
Number input strings	38x4	38x4	38x4	
MPPT voltage range (Vdc)	200-700	200-700	200-700	
AC Grid (output)				
Normal AC Voltage (V _{AC})	3P+PE/3P 133/230			
Frequency (Hz)	50			
Normal AC Current (A)	75.2	75.2	90.4	
Max. cont. output current (A)	87	87	96	
Normal Power (kW)	29.99	30	36	
Rated Apparent Power (kVA)	29.99	30	36	
Max. cont. Power (kW)	29.99	30	36	
Max. cont. Apparent Power (kVA)	29.99	30	36	
Power factor(adjustable)	1.0(-0.8~ +0.8)			
Others				
Protective class	Class I			
Ingress protection (IP)	IP66			
Temperature (°C)	-25°C to +60°C (Derating45°C)			
Inverter Isolation	Non-isolated			
Overvoltage category	OVC III (AC Main), OVC II (PV)			
Firmware version	1.01			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.